

## Lake Huron Water Treatment Plant 2009 Regulated Detected Contaminants Tables

Contaminant	Test Date	Units	Health Goal MCLG	Allowed Level MCL	Level Detected	Range of Detection	Violation yes/no	Major Sources in Drinking Water
<b>Inorganic Chemicals – Annual Monitoring at Plant Finished Water Tap</b>								
Fluoride	8/31/2009	ppm	4	4	1.26	n/a	no	Erosion of natural deposits; Water additive, which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate	8/31/2009	ppm	10	10	0.29	n/a	no	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Barium	6/9/2008	ppm	2	2	0.01	n/a	no	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Disinfectant Residuals and Disinfection By-Products – Monitoring in Distribution System</b>								
Total Trihalomethanes (TTHM)	Feb-Nov 2008	ppb	n/a	80	16.8	7.2-33.8	no	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	Feb- Nov 2009	ppb	n/a	60	10.4	6.7-16.4	no	By-product of drinking water disinfection
Disinfectant (Total Chlorine residual)	Jan-Dec 2009	ppm	MRDGL 4	MRDL 4	0.83	0.68-0.85	no	Water additive used to control microbes

<b>2009 Turbidity – Monitored every 4 hours at Plant Finished Water Tap</b>			
Highest Single Measurement Cannot exceed 1 NTU	Lowest Monthly % of Samples Meeting Turbidity Limit of 0.3 NTU (minimum 95%)	Violation yes/no	Major Sources in Drinking Water
0.12 NTU	100%	no	Soil Runoff
Turbidity is a measure of the cloudiness of water. We monitor it because it is a good indicator of the effectiveness of our filtration system.			

<b>2009 Microbiological Contaminants – Monthly Monitoring in Distribution System</b>					
Contaminant	MCLG	MCL	Highest Number Detected	Violation yes/no	Major Sources in Drinking Water
Total Coliform Bacteria	0	Presence of Coliform bacteria > 5% of monthly samples	in one month	no	Naturally present in the environment.
<i>E.coli</i> or fecal coliform bacteria	0	A routine sample and a repeat sample are total coliform positive, and one is also fecal or <i>E.coli</i> positive.	entire year	no	Human waste and animal fecal waste.

<b>2008 Lead and Copper Monitoring at Customers' Tap</b>								
Contaminant	Test Date	Units	Health Goal MCLG	Action Level AL	90 <sup>th</sup> Percentile Value*	Number of Samples Over AL	Violation yes/no	Major Sources in Drinking Water
Lead	2008	ppb	0	15	oppb	0	no	Corrosion of household plumbing system; Erosion of natural deposits.
Copper	2008	ppm	1.3	1.3	0.070 ppm	0	no	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.
*The 90th percentile value means 90 percent of the homes tested have lead and copper levels below the given 90th percentile value. If the 90th percentile value is above the AL additional requirements must be met.								

Regulated Contaminant	Treatment Technique	Running annual average	Monthly Ratio Range	Violation Yes/No	Typical Source of Contaminant
Total Organic Carbon (ppm)	The Total Organic Carbon (TOC) removal ratio is calculated as the ratio between the actual TOC removal and the TOC removal requirements. The TOC was measured each month and because the level was low, there is no requirement for TOC removal.				Erosion of natural deposits

### 2009 Special Monitoring

Contaminant	MCLG	MCL	Level Detected	Source of Contamination
Sodium (ppm)	n/a	n/a	4.74	Erosion of natural deposits

### Key to Detected Contaminants Tables

Symbol	Abbreviation for	Definition/Explanation
<b>MCLG</b>	Maximum Contaminant Level Goal	The level of contaminant in drinking water below which there is no known or expected risk to health.
<b>MCL</b>	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>MRDLG</b>	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
<b>MRDL</b>	Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
<b>ppb</b>	Parts per billion (one in one billion)	The ppb is equivalent to micrograms per liter. A microgram = 1/1000 milligram.
<b>ppm</b>	Parts per million (one in one million)	The ppm is equivalent to milligrams per liter. A milligram = 1/1000 gram.
<b>NTU</b>	Nephelometric Turbidity Units	Measures the cloudiness of water.
<b>ND</b>	Not Detected	
<b>TT</b>	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.
<b>AL</b>	Action Level	The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
<b>HAA5</b>	Haloacetic acids	HAA5 is the total of bromoacetic, chloroacetic, dibromoacetic, dichloroacetic, and trichloroacetic acids. Compliance is based on the total.
<b>TTHM</b>	Total Trihalomethanes	Total Trihalomethanes is the sum of chloroform, bromodichloromethane, dibromochloromethane, and bromoform. Compliance is based on the total.
<b>n/a</b>	not applicable	
<b>&gt;</b>	Greater than	

# 2009 WATER QUALITY REPORT FOR CITY OF IMLAY CITY

This report covers the drinking water quality for the City of Imlay City, for the calendar year 2009. This information is a snapshot of the quality of the water that we provided to you in 2009. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Imlay City purchases its water from the Detroit Water and Sewerage Department. Detroit Water and Sewerage Department has a water treatment plant north of Port Huron from which we get our water via a 72" transmission line that runs from Port Huron to Flint. The source for this treatment plant is Lake Huron. In July 2009 The City of Imlay City issued a boil water alert due to a break in a 16 inch water main in the distribution system for a 24-hour period. Samples were taken in accordance to State of Michigan requirements. All samples came back negative for Bact-t. Larry Lloyd or Brian Klaassen can answer any questions at 810-724-8712.

## **Mandatory language regarding contaminants reasonably expected to be found in drinking water.**

"Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organics, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health."

## **Warning about the vulnerability of some populations to contaminants in drinking water. (§151.154(a)).**

"Some people may be more vulnerable to contaminants in drinking water than is the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)."

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

**New LCR CCR requirements covering the year 2009 water supplies must include information about lead, even if lead is not detected: Replaces old language (see CCR letter from MDEQ 2009). Lead and Copper language required 40 CFR 141.154**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Imlay City is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Required 2009 Unregulated contaminant monitoring language for all the water plants:**

Unregulated contaminants are those for which EPA has not established drinking water standards. Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants. Beginning in April 2009, the Detroit Water and Sewerage Department (DWSD) began monitoring quarterly for unregulated contaminants under the Unregulated Contaminant Monitoring Rule 2 (UCMR2.) All the UCMR2 contaminants monitored on List 1 and List 2 in 2009 were undetected.

**Required language source water protection Detroit River intakes; for communities receiving water from one or more of the following water plants; Water Works Park, Springwells, Northeast, and Southwest.**

Your source water comes from the Detroit River, situated within the Lake St. Clair, Clinton River, Detroit River, Rouge River, Ecorse River, in the U.S. and parts of the Thames River, Little River, Turkey Creek and Sydenham watersheds in Canada. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is on a seven-tiered scale from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The susceptibility of our Detroit River source water intakes were determined to be highly susceptible to potential contamination. However, all four Detroit water treatment plants that use source water from Detroit River have historically provided satisfactory treatment of this source water to meet drinking water standards. DWSD has initiated source-water protection activities that include chemical containment, spill response, and a mercury reduction program. DWSD participates in a National Pollutant Discharge Elimination System permit discharge program and has an emergency response management plan. If you would like to know more information about this report or a complete copy of this report please, contact your water department (810) 724-8712 Brian Klaassen.

**Required language source water protection Lake Huron intake; for communities receiving water from the Lake Huron Plant:**

Your source water comes from the lower Lake Huron watershed. The watershed includes numerous short, seasonal streams that drain to Lake Huron. The Michigan Department of Environmental Quality in partnership with the U.S. Geological Survey, the Detroit Water and Sewerage Department, and the Michigan Public Health Institute performed a source water assessment in 2004 to determine the susceptibility of potential contamination. The susceptibility rating is a seven-tiered scale ranging from "very low" to "very high" based primarily on geologic sensitivity, water chemistry, and contaminant sources. The Lake Huron source water intake is categorized as having a moderately low susceptibility to potential contaminant sources. The Lake Huron water treatment plant has historically provided satisfactory treatment of this source water to meet drinking water standards. If you would like to know more information about this report or a complete copy of this report please, contact your water department (810) 724-8712 ext. 312 Brian Klaassen.